

HIMACHAL PRADESH JAL SHAKTI VIBHAG
WATER TESTING LABORATORY DIVISION NAGROTA BAGWAN

Collected By - Manoj kumar

On Dated - 21-06-2023

Date & Time Result - 23-06-2023

Source - Tap Water

Location - Maharana Pratap International Public School Dharamshala at Dharamgiri

Limits: Based upon BIS : 10500-2012

(A) PHYSICAL PARAMETERS					
Sr. No.	Parameter	Unit	Acceptable Limit	Permissible Limit	Result
1	Temperature	°C	30.1
2	Colour	Hazen Units	5	15	5
3	Odour	Agreeable	Agreeable	Agreeable
4	Taste	Agreeable	Agreeable	Agreeable
5	Turbidity	NTU	1	5	0.2
6	PH	6.5-8.5	No Relaxation	7.3
(B) CHEMICAL PARAMETERS					
7	TDS/ Electrical Conductivity	mg/l	500	2000	102
8	Total Hardness	mg/l	200	600	40
9	Total Alkalinity	mg/l	200	600	48
10	Chloride	mg/l	250	1000	18
11	Calcium	mg/l	75	200	10.4
12	Magnesium	mg/l	30	100	4.6
13	Nitrate	mg/l	45	No Relaxation	NIL
14	Iron	mg/l	1	No Relaxation	NIL
15	Manganese	mg/l	0.1	0.3	NIL
16	Sulphate	mg/l	200	400	10
17	Fluoride	mg/l	1	1.5	NIL
18	Free Residual Chlorine	mg/l	0.2	1	NIL
(C) BACTERIOLOGICAL PARAMETERS					
19	Total Coliforms	MPN/100 ml	NIL	NIL	NIL
20	E-Coli/Thermo Tolerant Coliforms	MPN/100 ml	NIL	NIL	-

This Water is Safe For Drinking Purpose

ASSISTANT CHEMIST
JAL SHAKTI VIBHAG
WATER TESTING LABORATORY, NAGROTA BAGWAN.

ASSISTANT ENGINEER,
JAL SHAKTI VIBHAG,
NAGROTA BAGWAN

Principal
Maharana Pratap International Public
School Dharamshala at Dharamgiri
P.O. Pathiar, District Kangra (H.P.)-178047

Manager
Maharana Pratap International Public
School Dharamshala at Dharamgiri
P.O. Pathiar, District Kangra (H.P.)-178047

Annexure C

Appendix-XIII

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 1000

Dated: 23-06-2023

It is certified that an inspection team headed by **Akhil Kumar Jr. Engineer Section Pathiar**

(Name of Officers with designation) from **JAL SHAKTI VIBHAG NAGROTA BAGWAN**

(Name of Department/ Office) inspected the **MAHARANA PRATAP INTERNATIONAL PUBLIC SCHOOL at Dharamgiri P.O. Pathiar Tehsil Nagrota Bagwaan District Kangra 176047-H.P**

(Name & Address of the school) on **22/06/2023** checked the water test report submitted by the school and found that the school has potable drinking water for students and staff of the institution and is having provision for running water in the toilets and maintaining hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of **3 Years**

Signature with Seal:

Name : **Abhishek Bhatia** Engineer
Jal Shakti Sub Division
Designation : **Asst. Eng.** Nagrota Bagwan

Assistant Engineer of
the Govt. Public Health Department (PHED)/
Authorised officer of the Local Body

Name & Address of the Office / Department :

To

Principal
MAHARANA PRATAP INTERNATIONAL PUBLIC SCHOOL
Principal
Maharana Pratap International Public
School Dharamshala at Dharamgiri
P.O. Pathiar, District Kangra (H.P.)-176047
(Name & Address of the Institution)

Manager
Maharana Pratap International Public
School Dharamshala at Dharamgiri
P.O. Pathiar, District Kangra (H.P.)-176047

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.